


Tank lifting limitations:
Max chain angle < 60°



Damage caused by incorrect lifting is the responsibility of others

Notes:

- Observe all safety regulations in regard to excavation and lifting requirements. Never leave opening uncovered or unattended at any time
- Specify any specific requirements prior to ordering. All civil works by customer
- Do not scale from this drawing. Only for illustration purposes
- Rainwater from roofs only
- Manhole chamber and pipework by others (marked in grey)
- Risers by contractor or as required
- Optional mains-part-fill-make-up-valve in header or RWH tank (BS8515 compliant with >36mm AA air gap)
- Float switches must be installed at heights as per this drawing
- Rainwater input from roofs only



Clara Rd., Tullamore, Co. Offaly
T: 057 9326000 E: info@molloyprecast.com
F: 057 9326060 W: www.molloyprecast.com



Title: 38,000L Rainwater Harvesting System

Drg. no.: RW-R-GEP-001-120520

Tank Volume: 38,000L

Rainwater Storage: 33,000L

Date: 12/05/2020

Drawn by: SF